






	Individual Fans				Fan Array
					
	GTx108e-F/SI (SWSI Fans)	GTx108e-F/DI (DWDI Fans)	HTx104-F/SI (SWSI Fans)	HTx104-F/DI (DWDI Fans)	GTx108e-F / An
# Sensor Nodes	up to 2	up to 4	up to 2	up to 4	up to 8
Measurement Output	Airflow Temperature	Airflow Temperature	Airflow Temperature	Airflow Temperature	Airflow Temperature
Accuracy	Airflow: $\pm 2\%$ of reading to NIST-traceable airflow standards Temperature: $\pm 0.15^\circ\text{F}$ [0.08°C] to NIST-traceable temperature standards				

Connectivity Options (Model code placeholder x= A, C, F, M, N, or U)

Linear Analog Output Signals (AO1, AO2)	A	A	A	A	A
BACnet MS/ TP or Modbus RTU	C	C	N	N	C
BACnet Ethernet or BACnet IP, Modbus TCP and TCP/IP	M	M			M
LonWorks Free Topology	F	F			F
USB "Thumb Drive" Datalogger	U	U			U
NIST Traceable Calibration	✓	✓	✓	✓	✓
Alarms	✓	✓	✓	✓	✓
EB-Link App	✓	✓			✓
Mounting Options	Throat Forward Face Flare Cantilever	Throat Forward Face Flare Cantilever	Throat Forward Face Flare Cantilever	Throat Forward Face Flare Cantilever	Throat Forward Face Flare Cantilever